

C-102

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Hospital/2024/SZ/ 20

Dated: 09/01/2025

To,

The Authorized Signatory,
M/s 100 Bedded Colony Hospital Building
Tilak Nagar, New Delhi- 110018.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. M/s 100 Bedded Colony Hospital Building at Tilak Nagar, New Delhi- 110018.

Sir,

This has reference to your Letter No. Form "J" dated 02.12.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the hospital building on dated 02.1.2025 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Vinay Sharma, AE (Elect.) was also present and it was observed that the hospital building is comprised of Basement, ground plus five upper floors and have following shortcomings.

1. Sealing of Electrical Shaft found not provided.
2. Ventilation system found not functional in basement and upper floors level.
3. Hose reels/hydrants found provided but found not functional.
4. Smoke/Heat detectors found Provided but not functional.
5. MOEFA provided but found not functional.
6. PA system provided but found not functional
7. Underground fire pumps and terrace level fire pump provided but found not functional in auto mode.
8. Exit Signes found removed at some places.

Keeping in view of above, issuance of Fire Safety Certificate can-not be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Arul Garg)
Director

Delhi Fire Service

Copy for information: -.

1. MS, Nursing Homes, DGHS, Govt of NCT of Delhi, S-1, 3rd Floor, School Block, Shakarpur, Delhi-110092.
2. The Executive Engineer (Elect.), MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027.