

c-54

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/III/2026/WZ/ 646

Dated: 07/07/2026

To,

The Owner/Occupier,
Symposium Restaurant
101, 1st floor, City Centre Mall, Plot No. 05,
Sec. 12, Dwarka, New Delhi- 110075.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s. Symposium at Unit No. 101, 1st floor of City Centre Mall, Plot No. 05, Sec. 12, Dwarka, New Delhi- 110075.


Sir,

This has a reference to MCD online application ID No. 2026060307966 dated 06.05.2026, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the eating house/ restaurant building on dated 29.06.2026 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Manager was present and it was observed that the restaurant/ eating house is running at first floor of City Centre Mall Building comprised of two basements, ground plus five upper floors, and following shortcomings were observed: -

1. Exit Door found closed and found seating arrangement in the exit way/ passage.
2. MOEFA system provided but found not functional.
3. Exit Signs found removed at some places.

Keeping in view of the above, renewal of fire safety certificate can-not be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department, and running eating house/ restaurant in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully



(S.K. Dua)

Chief Fire Officer
West Zone

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi, w.r.t. MCD Portal ID -. 2026060307966 dated 06.05.2026.