

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2026/SZ/ 632

Dated: 09/07/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s. Green Lotus Residency guest house located at 1st, 2nd & 3rd floor, Plot No. 91, Block-B, Sector- 13, Dwarka, New Delhi- 110075, in a building comprised of basement, stilt, ground plus 03 upper floors, using basement (closed & others property), ground floor (SBI Bank), 1st & 2nd floor (06 guest rooms each), 3rd floor having 01 guest room (total 13 guest rooms), was issued FSC by this department vide letter F.6/DFS/MS/2023/SZ/GH/82 dated 04.05.2023. The premises was re-inspected by the officer concerned of this department on dated 16.06.2026 in the presence of Mr. Rajender Singh, and found that the guest house have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi fire service Rules 2010 and that the building/premises is fit for occupancy class "Residential" (Guest house) (total 13 guest rooms at 1st, 2nd & 3rd floor) w.e.f. 09/07/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 09/07/2026 at New Delhi.

(Signature)
 08/07/26
 (S.K. Dua)

Chief Fire Officer
 West Zone

Copy to: -

1. The Commissioner, MCD, Delhi: with a request to ensure the occupancy as detailed above and deviation, if any.
2. Online application Id 2026060408014 dated 08.06.2026.
3. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.

: - for information regarding use of basement.

Conditions for the validity of fire safety certificate: -

1. The FSC issued only for guest house running at 1st, 2nd & 3rd floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Presently basement used for others property and closed.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Green Lotus Residency located at 91, Block-B, Pocket- 10, Sector- 13, New Delhi- 110075.
2. Building is comprised of : B, stilt, Gr.+3 upper floors, using Basement (Closed), stilt (parking), Ground floor (SBI Bank), 1st & 2nd floor (06 guest rooms each), 3rd floor having 01 guest rooms (total 13 guest rooms only).
3. Type of Occupancy : Residential (Guest House)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/2023/SZ/GH/82 dated 04.05.2023
6. Fire Safety direction letter No : BBL/UBBL
7. Date of Inspection : 16.06.2026
8. Name of the Inspecting officers : ADO R.K. Yadav (DWK)
9. Name and designation of officer from the building side : Mr. Rajender Singh
10. Year of construction : 2017
11. Applicant's letter No : ID No. 2026060408014 dated 08.06.2026 **Old Case**

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirements as per FSC dt. 04.05.2023	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	18.0 m	Provided	MR
	• Gate width	4.5 m	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	-	-	-
	• Upper floor	02 nos.	Provided	MR
	• Basement	N/A	N/A	Other property
	B. Width of Staircases	-	-	-
	• Upper floor	1.50 m & 1.0 m	1.50 m & 1.25 m	MR
	• Basement	N/A	N/A	Other property
	c. Protection of Exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02	Provided	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	1.50 m & 1.25 m	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	Other property
	• Upper floor	12 ACPH	Exhaust fans provided	MR
5.	Fire Extinguishers.			
	• Total numbers	15 nos.	Provided	MR
	• ABC/CO ₂	ABC/CO ₂	Provided	MR

	- Total numbers on each floor - Length of hose reel hose - Nozzle diameter	01 No. 30 m 05 mm	Provided Provided Provided	MR MR MR
07	Automatic Fire Detection, CO detection and Alarming System.			
	- CO Type of detectors - Location of main panel - Location of repeater panel - Alternate source of power - Hooter's location	Carbon Monoxide Required N/A Required Required	Provided Ground Floor N/A Provided Corridor	MR MR N/A MR MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	- Basement - upper floor - sprinkler above false ceiling	N/A N/A N/A	N/A N/A N/A	Other property N/A N/A
11	Internal Hydrants			
	- size of riser/down-comer - Number of hydrants per floor - Hose box	100 mm 01 nos. Required	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	- Total number of hydrants - Hose box	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	- Discharge of main pump - Head of main pump - Number of main pumps - Jockey pump out put - Jockey pump head - Standby pump out put - Standby pump head - Auto starting /manual stopping - Pump house access	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A
	➤ Terrace Level			
	- Discharge of pump - Head of the pump - Power supply - Auto Starting of pump	450 LPM 30 m Required Required	Provided Provided Provided Provided	MR MR MR MR
14	Captive Water Storage for Fire Fighting.			
	- Underground tank capacity - Draw-off connection - Fire service inlet - Access to tank - Overhead Tank capacity	N/A N/A N/A N/A 10,000 ltrs	N/A N/A N/A N/A Provided	N/A N/A N/A N/A MR
15	Exit Signage.	Required	Provided	MR

N/29

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided DG Set 125 KVA	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - As per affidavit submitted by guest house management (placed at C-75) that the guest house building comprised of basement, stilt, ground plus 03 upper floors, using basement (closed & others property), ground floor (SBI Bank), 1st & 2nd floor (06 guest rooms each), 3rd floor having 01 guest rooms respectively (total 13 guest rooms).

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/2023/SZ/GH/82 dated 04.05.2023, **renewal under rule 37** of the Delhi Fire Service Rules 2010, **is recommended.**

R.K. Yadav
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (DWK)

DO (SW)

18/6/26
RAJINDER ATWAL

Defo (W2)

23/06/2026

Cfo (W2) - on Leave

Principal Director

Cfo (W2)

ADO (DWK)

Cfo to issue F.T. please. *8/2*
Living
06/07/26

N/30

FT letter is put up for sign means

R/Ces
7/7/2026

~~CFO (W/2)~~

Limp
08/07/26

F.P. wing

Updated.
10/7/26
Q1.