

e-38



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

75
 आज़ादी का
 अमृत महोत्सव


No:F6/DFS/MS EH/NZ/2026/ 587

Dated: 29/06/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s KFC (A Unit of Sapphire Foods India Limited) located at Shop No. 85 & 87, Ground Floor, GTB Nagar, Model Town, Delhi 110009, in a building comprised of Basement, ground + 02 upper floor but restaurant is running at ground floor only was earlier granted FSC by this department vide letter No. F6/DFS/MS/EH/2023/EH/228 dated 17.07.2023. Now, the premises was re-inspected by the officer concerned of this department on 20.06.2026 in the presence of Manager and observed that the restaurant premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" (Group- D), (restaurant running at ground floor only) with effect from 29/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 29/06/2026 at New Delhi by


 29/6/26
 (Dr. S. K. Tomar)
 Chief Fire Officer
 Delhi Fire Service
 01/2 24/11

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi - 02, w.e.f. ID No. 2026050406325 dated 03.06.2026.
2. The Licensee, M/s KFC (A Unit of Sapphire Foods India Limited) at Shop No. 85 & 87, Ground Floor, GTB Nagar, Model Town, Delhi - 110009.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA Portal (<https://www.dehhlhlic.gov.in>) along with a copy of this certificate, six months prior to its expiry.
9. This FSC is valid for ground floor (restaurant) only.

INSPECTION REPORT

1.	Name and address of the building	M/s KFC (A Unit of Sapphire Foods India Limited) located at Shop No. 85 & 87, Ground Floor, GTB Nagar, Model Town, Delhi 110009.		
2.	Composition of Building	Basement, Ground & 02 upper floors but restaurant running at ground floor only		
3.	Type of occupancy with details of floors	Assembly (Restaurant)		
4.	Type of case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/EH/2023/EH/228 dated 17.07.2023		
6.	Fire safety directives no.	NA		
7.	Date of inspection	20.06.2026		
8.	Name of the inspecting officer	ADO (MT)		
9.	Name and designation of the officer from the building side	Manager		
10.	Year of construction	2010 (as per MCD Portal ID)		
11.	Reference letter no.	MCD portal online application ID No. 2026050406325 dated 03.06.2026		

S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements NBC Part-IV	Provided at site	Remarks MR/NMR
1	Access to Building			
	A Road width	08 mtr	10 m approx..	MR
	B Gate width	NA	NA	NA
	C Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	A No. Of Staircase:			
	a) Upper Floor	NA	NA	NA
	b) Basements	NA	NA	NA
	B Width of the Staircase:			
	a) Upper floors	NA	NA	NA
	b) Basements	NA	NA	NA
	C Protection of Exits			
	a) Fire Check Door	NA	NA	NA
	b) Pressurization	NA	NA	NA
	D No. Of continuous staircase to terrace:	NA	NA	NA
	E Width of the corridor	NA	NA	NA
	F Door size	1.5 mtr. each	1.5 mtr. each	MR
3	Compartmentation:			
	A Fire Check doors	NA	NA	NA
	B Sealing of Electrical Shafts	NA	NA	NA
	C Fire rating of shaft Doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke management System:			
	A Basements	NA	NA	NA
	B Upper floors (Ground Floor)	Required	Provided	MR
5	Fire extinguishers			
	A Total numbers	04 nos.	Provided	MR
	B Types	CO ₂ , ABC	Provided	MR
	C ISI marking	Required	Provided	MR

6	First Aid Hose reel				
	A	Total no. at each floor	01 no.	Provided	MR
	B	Length of Hose Reel	30 mtr.	Provided	MR
	C	Nozzle diameter	05 mm	Provided	MR
7	Automatic Fire Detection and Alarm System (ADAS):				
	A	Type of Detectors	NA	NA	NA
	B	Location of main Panel	NA	NA	NA
	C	Location of Repeater Panel	NA	NA	NA
	D	Alternate power Source	NA	NA	NA
	E	Hooter's location	NA	NA	NA
8	MOEFA		Required	Provided	MR
9	Public Address System		NA	NA	NA
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper Floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	100 mm	Provided	MR
	B	No. Of hydrants per floor	01 no.	Provided	MR
	C	Hose box per floor	01 no.	Provided	MR
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge of main pump	NA	NA	NA
		b) Head of main pump	NA	NA	NA
		c) Number of main pump	NA	NA	NA
		d) jockey pump output	NA	NA	NA
		e) Head of jockey pump	NA	NA	NA
		f) Standby pump output	NA	NA	NA
		g) Head of Standby pump	NA	NA	NA
		h) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	450 LPM	Provided	MR
		b) Head of terrace pump	40 mtr.	Provided	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	20,000 ltrs.	20,000 ltrs.	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		Required	Provided	MR

(M/s KFC (A Unit of Sapphire Foods India Limited) at Shop No. 85 & 87, Ground Floor, GTB Nagar, Model Town, Delhi)

18	Refuge Area			
A	Location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room:			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any			NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. **F6/DFS/MS/EH/2023/EH/228 dated 17.07.2023 renewal (restaurant running at ground floor only)** under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Accordingly, DFA is put up for kind perusal, approval and signature please.

[Signature]
22/06/2026

Signature of the Inspecting Officer

Name - Sumit Kumar

Designation - ADO(MT)

DO (CNW)

[Signature]
22/6

[Signature]
CFO/N2

[Signature]
23/6/23

[Signature]
Principal Director

CFO to *[Signature]*

[Signature]
22/06/26

[Signature]
CFO (ECN)

[Signature]
24/6/26

ADO/MT

F.T. letter is put up for signature, please.

[Signature]
29/06/2026

[Signature]
CFO (N2)

[Signature]
23/6/26