



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/Hotel/SZ/2026/642

Dated: 07/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Bamyan The Boutique Hotel (Guest House) located at 6-A, Ring Road, Lajpat Nagar-IV, New Delhi-24,

Sir,

With reference to the elt.mcdonline application no. 20260300102242. on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 23/06/2026 in the presence of Mr. Prayag Singh Rawat (Reservation Manager) and following shortcomings were observed.

1. All Water Based Systems like Fire Pumps, Hose Reels, are non- functional.
2. No Smoke ventilation system provided, Natural Ventilation system closed by glass air tight windows.

In view of above shortcomings, the application of renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(A.K. Malik)

Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Owner/Occupier/Manager, Bamyan The Boutique Hotel (Guest House) located at 6-A Road, Lajpat Nagar-IV, New Delhi-24.