



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2026/School/ 613

Dated: 03/07/2026

To,

Bal Vidya Model School,
B-247, Laxmi Park, Nangloi,
New Delhi-110041.

Sub: Issue of FSC in r/o Bal Vidya Model School, located at B-247, Laxmi Park, Nangloi, New Delhi-110041.

Sir,

Kindly refer to online application ID-52026050602730 dated 25.05.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 15.06.2026, in presence of Mr. B. S. Dabas (Manager) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for **renewal of FSC is rejected** under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. The First Aid Hose Reel has been provided; however, it was found non-functional, and the nozzles of the hose reel were found missing.
2. Terrace Fire pump with capacity of 450 LPM provided but non-functional and not operating in auto mode.
3. An Overhead Captive Water Tank of 8,000ltr capacity has been provided against the required capacity of 10,000ltr.
4. Exit signage's found removed at some places.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service