



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/ECN/2026/621

Dated: -04/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding Issuance of Fire Safety Certificate in r/o M/s Mannat International, 9336-45, Multani Dhanda, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026060608296 dt. 06/06/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 25/06/2026 in the presence of Sh. Lekh Raj, Manager and following shortcomings were observed:-

1. Automatic detection system found removed.
2. Automatic operation of fire pump found removed.
3. Hose reel found missing at ground floor.
4. Domestic connection in overhead water storage tank is not permitted.
5. Alternate staircase of 1.5-mtr width found removed in the building.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,



(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

01CBP

Copy to: -

1. The Manager, M/s Mannat International, 9336-45, Multani Dhanda, Paharganj, New Delhi - 110055.