



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI – 110001




No:F6/DFS/MS EH/NZ/2026/ 588

Dated: 29/06/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Dasaprakash (A Unit of DAS Kitchens) located at Plot No. 35, Block – B1, Upper Ground floor, Ashok Vihar Phase II, New 110052, owned/occupied by M/s DAS Kitchen, was earlier granted FSC by this department vide letter No. F6/DFS/MS/EH/WZ/2023/59 dated 13.02.2023. Now, the premises was re-inspected by the officer concerned of this department on 19.06.2026 in the presence of Mr. Avinash (Manager) and observed that the management have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class “Assembly” (Group- D), (restaurant at Upper ground floor only) with effect from 29/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 29/06/2026 at New Delhi by


29/6/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

o/c 29/6

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi - 02, w.e.f. ID No. 2026060408079 dated 04.06.2026.
2. The Licensee, M/s Dasaprakash Restaurant at Plot No. 35, Block – B1, Upper Ground floor, Ashok Vihar Phase II, New 110052.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA Portal (<https://www.dehhlhlic.gov.in>) along with a copy of this certificate, six months prior to its expiry.
9. This FSC is valid for the Restaurant at upper ground floor only.

INSPECTION REPORT

1.	Name and address of the building	M/s Dasaprakash (A Unit of Das Kitchens) located at Plot No. 35, Block-B1, Upper Ground Floor, Ashok Vihar, Phase-II, Delhi-110052.		
2.	Type of occupancy with details of floors	Assembly (Restaurant)		
3.	Type of case	Renewal		
4.	Details of previous NOC	F6/DFS/MS/EH/WZ/2023/59 dated 13.02.2023		
5.	Fire safety directives no.	NA		
6.	Date of inspection	19.06.2026		
7.	Name of the inspecting officer	ADO (MT)		
8.	Name and designation of the officer from the building side	Mr. Avinash (Manager)		
9.	Year of construction	2018 (as per MCD Portal ID)		
10.	Reference letter no.	MCD portal online application ID No. 2026060408079 dated 04.06.2026		

S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (as per Rule 35 (6) of DFS Rules 2010)	Provided at site	Remarks MR/NMR
1	Access to Building			
	A Road width	12 mtr	Provided	MR
	B Gate width	4.5 mtr.	Provided	MR
	C Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	A No. Of Staircase:			
	a) Upper Floor	02 Nos.	03 nos.	MR
	b) Basements	NA	NA	NA
	B Width of the Staircase:			
	a) Upper floors	1.5 m each	01 no.-2.08 mtr. & 02 nos.-1.5 m each	MR
	b) Basements	NA	NA	NA
	C Protection of Exits			
	a) Fire Check Door	NA	Provided	NA
	b) Pressurization	NA	NA	NA
	D No. Of continuous staircase to terrace:	02 nos.	Provided	MR
	E Width of the corridor	NA	NA	NA
	F Door size	1.5 mtr.	Provided	MR
3	Compartmentation:			
	A Fire Check doors	NA	NA	NA
	B Sealing of Electrical Shafts	NA	NA	NA
	C Fire rating of shaft Doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke management System:			
	A Basements	NA	NA	NA
	B Upper floors	Required	Natural ventilation	MR
5	Fire extinguishers			
	A Total numbers	08 nos.	Provided	MR
	B Types	CO ₂ , ABC	Provided	MR
	C ISI marking	Required	Provided	MR

6	First Aid Hose reel					
	A	Total no. at each floor	01 no.	Provided		MR
	B	Length of Hose Reel	30 mtr.	Provided		MR
	C	Nozzle diameter	05 mm	Provided		MR
7	Automatic Fire Detection and Alarm System (ADAS):					
	A	Type of Detectors	NA	Provided		NA
	B	Location of main Panel	NA	Provided		NA
	C	Location of Repeater Panel	NA	NA		NA
	D	Alternate power Source	NA	Provided		NA
	E	Hooter's location	NA	Provided		NA
8	MOEFA		Required	Provided		MR
9	Public Address System		NA	NA		NA
10	Automatic Sprinkler System					
	A	Basement	NA	NA		NA
	B	Upper Floor	NA	NA		NA
	C	Sprinklers above false ceiling	NA	NA		NA
11	Internal hydrants					
	A	Size of the riser/down comer	100 mm	Provided		MR
	B	No. Of hydrants per floor	01 no.	Provided		MR
	C	Hose box per floor	01 no.	Provided		MR
12	Yard Hydrants					
	A	Total no. of hydrants	NA	NA		NA
	B	Hose box	NA	NA		NA
13	Pumping arrangements					
	A	Ground Level				
		a) Discharge of main pump	NA	NA		NA
		b) Head of main pump	NA	NA		NA
		c) Number of main pump	NA	NA		NA
		d) jockey pump output	NA	NA		NA
		e) Head of jockey pump	NA	NA		NA
		f) Standby pump output	NA	NA		NA
		g) Head of Standby pump	NA	NA		NA
		h) Auto starting/ manual stopping	NA	NA		NA
	B	Terrace Level				
		a) Discharge of terrace pump	450 LPM	Provided		MR
		b) Head of terrace pump	40 mtr.	Provided		MR
		c) Alternate power supply	Required	Provided		MR
		d) Auto starting of pump	Required	Provided		MR
14	Captive Water Storage for Fire Fighting					
	A	Underground tank capacity	NA	NA		NA
	B	Draw off connection	NA	NA		NA
	C	Fire Service Inlet	NA	NA		NA
	E	Access to tank	NA	NA		NA
	D	Overhead tank capacity	20,000 ltrs.	Provided		MR
15	Exit Signage		Required	Provided		MR
16	Provision of lift					
	A	Pressurization of lift shaft	NA	NA		NA
	B	Pressurization of lift lobby	NA	NA		NA
	C	Communication in lift car	NA	NA		NA
	D	Fireman switch	Required	Provided		MR
	E	Lift signage	Required	Provided		MR
17	Standby Power Supply		Required	Provided		MR

(M/s Dasaprakash at Plot No. 35, Block-B1, Upper Ground Floor, Ashok Vihar, Phase-II, Delhi)

18	Refuge Area			
	A	Location	NA	NA
	B	Total area	NA	NA
19	Fire Control Room:			
	A	Fire Detection System panel	NA	NA
	B	Flow switch panel	NA	NA
	C	P A system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plan	NA	NA
20	Special Fire Protection for special risk if any			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Shortcoming communicated vide letter no.F6/DFS/MS/WZ/EH/2026/190 dated 03.03.2026 have been rectified.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/EH/WZ/2023/59 dated 13.02.2023 renewal (restaurant at upper ground floor only) under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Sumit
24/06/2026

Signature of the Inspecting Officer

Name - Sumit Kumar

Designation - ADO(MT)

DO (CNW)

11
2016

CFO/NZ

QDomm
23/6/26

Principal Director

CFO to Issue

CFO (ECN)

Q
23/06/26

QDomm
24/6/26

ADO/FIT

F.T. letter is put up for signature, Please.

CFO (NZ)

Sumit
29/06/2026

QDomm
29/6/26

ms

uploaded