



e-37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



No F 6/DFS/MS/2026/EH/NZ/ 618

Dated: 07/07/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Kaleva Food Restaurant Located at Shop No. GD – 28, GF, Pitampura, Delhi – 110034 is running at Ground floor in a building comprised of Basement, Ground plus Three upper floors was issued FSC by this department vide letter No F6/DFS/MS/EH/WZ/2023/96 Dated 09/03/2023. The premise was re-inspected by the officer concerned of this department on 23.06.2026 in the presence of Mr. Mohit and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy class “Assembly” (Group D) Restaurant at Ground Floor only with effect from ..07/07/2026.. for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on07/07/2026. at New Delhi, by

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Delhi- to ensure the occupancy as detailed above and deviation if any- (Ref- MCD Portal ID No. 2026061008660).
2. The Owner/ Occupier, M/s. Kaleva Foods, Shop No. GD-28, Ground Floor, Pitampura, New Delhi – 110034.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. Basement Shall be used as per BBL.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MCD portal (<https://www.mcdonline.nic.in>) along with a copy of this Certificate, six months prior to its expiry”.
8. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. FSC is valid for restaurant at Ground Floor only.

INSPECTION REPORT

1. Name & address of the building : M/s Kaleva Foods Located at Shop No. GD – 28, GF, Pitampura, Delhi-110034
2. Type of Occupancy : Assembly (Restaurant)
3. Building Comprised of : Basement, Ground plus Three upper floors. (**Kaleva Foods Restaurant is running in Shop no. GD-28, Ground floor**)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/EH/WZ/2023/96 Dated- 09/03/2023
6. Fire Safety directives letter No : N/A
7. Date of inspection : 23/06/2026
8. Name of Inspecting Officer : R.K.Sinha, ADO (Shalimar Bagh)
9. Name and designation of officers
From the building side : Mr. Mohit
10. Year of Construction : 2010 as per MCD Portal
11. Applicant's letter No. : MCD Application ID No. 2026061008660 dated 10/06/2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per inspection report dated 01/06/2026	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	12 m	Provided	MR
	Gate width	4.5 m	On Road	MR
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	NA	Restaurant is running at GF floor	MR
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	NA	Restaurant is running at GF floor	MR
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	NA	NA	NA
	Width of Corridor	NA	NA	NA
	Door Size	02 x 1.5 m	Provided but 01 exit through Kitchen	MR
3.	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	NA	NA	NA
	Upper floors	Mechanical/ Natural ventilation	Natural ventilation	MR
5.	Fire Extinguishers			
	Total numbers	08 Nos.	Provided	MR
	Types	ABC/Co2 Type	ABC/ Co2	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR

	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	01 No.	Provided	MR
	Hose Box	01 No.	Provided	MR
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	450 lpm	Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			

	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter of even no. 562 dated 09/06/2026.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is **recommended to renew** the fire safety certificate issued vide letter number F6/DFS/MS/EH/WZ/2023/96 Dated 09/03/2023 under rule 37 of the Delhi Fire Service Rules, 2010.

Ado (S.B.)
24/6/26

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/Shalimar Bagh.

Do (CND)
11/29/26

Cfo (N2)

29/6/26

Principal Director

Cfo to some

2/2

Cfo (N2)

37/126

ADD/S.B. Sm. F-7 letter in progress

Ado (S.B.)
4/7/26

Cfo (N2)

4/7/26

ms needed