



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज्ञापीता
अमृत महोदय

No. F6 /DFS/MS/SCHOOL/WZ/2026/ 651

Dated: 08/07/2026

To,

The Authorized Signatory,
Shanti Gyan International School
Goyla, Najafgarh, New Delhi-110071.

Subject: - Regarding grant of Fire Safety Certificate in r/o Shanti Gyan International School located at Goyla, Najafgarh, New Delhi-110071.

Sir,

This has a reference to your letter received vide Online Application No. 52026052003057, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 18/06/2026 in the presence of Mr. Tilak Raj Khurana and observed that building comprised of Four Blocks, Block – A Ground + 03 floors, Block – B Ground + 3 floors, Block – C Ground + 2 floors & Block – D Ground floor only. School running on Block – A (G + 3 upper floors only), following shortcomings were observed during the inspection:

1. First Aid Hose Reel provided but found nonfunctional.
2. Terrace Level Pump is of 900 LPM provided but found nonfunctional.
3. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

08/07/26

(S. K Dua)
Chief Fire Officer
Delhi Fire Service
o/c

Copy to: -

1. The Director of Education, (GNCT), Old Secretariat, Civil Line, Delhi- 110054.