



C 78

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/GH/2026/NDZ/ 610

Dated: 06/07/2026

FIRE SAFETY CERTIFICATE

Certified that the **Akash Guest House at 17, Main Road Village Gazipur, Delhi 110096**, building comprised of Ground +03 upper floors but **Guest House running at 1st & 2nd upper floor only** (ground floor shop, 1st floor-06 guest rooms, 2nd floor-18 guest rooms 3rd floor laying vacant) owned/occupied by **Akash Guest House**, was issued FSC vide letter No. F.6/DFS/MS/GH/NDZ/2023/205 dated 27/12/2023. The premises was re-inspected by the officer concerned of this department on dated 23/06/2026 in the presence of Mr. Pawan Sharma (Owner) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Class "**Residential "Group-A (Guest House at 1st & 2nd Floor)**" with effect from 06/07/2026 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....06/07/2026.....at New Delhi by

4/7/26

(Dr. S. K. TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE OFFICER

To:-

- o/c
1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
MCD ID NO 20260608337
 2. The Owner, Akash Guest house located at 17, Main Road Village Gazipur, Delhi-110096

Conditions for the validity of Fire Safety Certificate:-

1. FSC is valid for 1st floor and 2nd floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/31

1. Name & address of the building : M/s Akash Guest House at 17, Main Road Vill-Ghazipur, Delhi, 110096
2. Type of Occupancy : Residential (Guest House)
3. Building is comprised of : G+ 3 upper Floors, Guest House is Running at First & Second floor only, Ground – Shop, 3rd floor lying vacant (affidavit enclosed)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/GH/NDZ/2023/205 dt 27/12/2023
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 23/06/2026
8. Name of the Inspecting officers : ADO (Shahdara), Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Pawan Sharma (owner)
10. Year of Construction : 2000
11. Applicant's letter No : 2026060608337 dated 06/06/2026

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement Existing fire safety arrangements	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	06 mtr	12 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 mtr.	1.5 mtr & 1.2 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos	2 nos	MR
	e. Width of Corridor	1.5 mtr	1.7 mtr & 2.90 mtr	MR
	f. Door Size	1.0 mtr.	1.0 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Ventilated	MR
05.	Fire Extinguishers.			
	• Total numbers	08 nos.	10 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	Required	Provided	MR

N/32

06	First-aid-Hose Reels.			
	Total numbers on each floor	02 No.	02 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors CO	Required	Provided	MR
	• Location of main panel	Gr. floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	02 nos.	N/A
	• Hose Box	N/A	02 nos.	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 Lpm.	2 x 450 Lpm.	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/33

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter no. F.6/DFS/MS/GH/NDZ/2023/205 dated 27/12/2023. **renewal under Rule 37 of the Delhi Fire Service Rules 2010, is recommended.**

Deepak
29/06/2026.
Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Shahdara)

DO (ED)

Deepak
29/06/26

CFO (ECN)

Deepak
29/06/26

Principal Director

CFO to solve.

Deepak
2/6

CFO (ECN)

Deepak
31/7/26

ADO/Shah.

Sir,
F.T. Letter is put up for your kind signature
pl.

CFO (ECN)

Deepak
1/7/26