

e 57

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2026/SZ/ 97

Dated: 09/07/2026

FIRE SAFETY CERTIFICATE

Certified that the Delhi Jain Public School located at Plot No. 12, Railway Road, Palam Colony, New Delhi- 110077, comprised of ground floor plus two upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2023/School/556 dated 17.08.2023. The school building was re- inspected by the officer concerned of this department on dated 17.06.2026 in the presence of Mr. Pankaj Jain, and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises (ground plus two upper floors) is fit for occupancy class "Educational Building" w.e.f. 09/07/26 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 09/07/2026 at New Delhi by.


08/07/26
(S.K. Dua)

Chief Fire Officer
West Zone

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Delhi Jain Public School located at Plot No. 12, Railway Road, Palam Colony, New Delhi- 110077.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/A

INSPECTION REPORT

1. Name & address of the building : Delhi Jain Public School at Plot No. 12, Railway Road, Palam Colony, New Delhi- 110077.
2. Building comprised of : Ground plus two upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/2023/School/556 dated 17.08.2023
6. Fire Safety directives letter No : DOE Circular No. 3298-3398 dated 01.03.2011
7. Date of inspection : 17.06.2026
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Pankaj Jain
10. Year of Construction : 1973
11. Applicant's letter No. : ctl.mcdonline Application No. 52026060103320

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dated 17.08.2023	Provided at site	Remarks MR/NMR
1.	Access to building			
	- Road width - Gate width - Width of internal road	6.0 m 4.5 m N/A	Provided Directly assessable from road N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	- Upper Floors - Basements	04 No's N/A	Provided N/A	M/R N/A
	b. Width of staircases			
	- Upper Floor - Basements	1.50 m each N/A	1.5 m & 1.0 m (03 nos.) N/A	MR, old case N/A
	c. Protection of exits			
	- Fire check door - Pressurization	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	02 nos.	Provided	M/R
	e. Width of Corridor	1.50 ,	1.5 m to 2.25 m	MR
	f. Door Size	1.0 m	Provided	M/R
3.	Compartmentation			
	- Fire check door - Sealing of electrical shafts - Fire Rating of shaft door - Water Curtain - Fire Dampers	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	- Basements - Upper floors	N/A 12 ACPII	N/A Natural ventilation	N/A M/R
5.	Fire Extinguishers			
	- Total numbers - Types - IS marking	30 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Ree			
	- Total numbers at each floor - Length of hose reel hose	03 nos. 30 M 5 mm	Provided Provided Provided	M/R M/R M/R

N/19

	- Type of detectors - Location of Main Panel - Location of Repeater Panel - Alternate source of power - Hooters' Location	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	Basement	N/A	N/A	N/A
	Ground Floor	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	Size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	03 Nos.	03 Nos.	MR
	Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	- Ground Level - Discharge of main Pump - Head of Main pump - Number of main pumps - Jockey Pump out put - Jockey pump head - Standby Pump out put - Standby Pump Head - Auto Starting/Manual Stopping	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	Pump House Access	N/A	N/A	N/A
	- Terrace level - Discharge of pump - Head of the pump - Power Supply - Auto Starting of pump	450 LPM	450 LPM & 180 LPM	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	- Underground tank capacity - Draw-off connection - Fire service inlet - Access to tank - Overhead Tank capacity	N/A	50,000 ltrs.	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. No Lift			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication In lift Car	N/A	N/A	N/A
	Fireman's Grounding Switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A

N/20

18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	Co2 type Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/2023/School/556 dated 17.08.2023, **is recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.

R.K. Yadav
 18/8/2026
 Signature of the Inspecting Officer
 Name:-R.K. Yadav
 Designation: - ADO (DWK)

DO (SW)

R.K.

25/6/26

DOFO (WZ)

23/06/2026

CFO (WZ) - on leave

Principal Director

CFO to issue

May

CFO (WZ)

F.T. please.

3/2

21/7/26

ADO (DWK)

RT letter & put up for signature

R.K.

21/7/2026

LIVE