

CB1

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/SZ/GH/2026/ 638

Dated: 07/07/2026

To,

The Commissioner MCD,
Dr. S.P.M. Civic Centre, Minto Road,
New Delhi-110002.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s JPM Majestic Guest House.
located at D-52, East of Kailash, New Delhi- 110065.

Sir,

Please refer to your online application letter No. 2026060908550 dated 10/06/2026, on the subject cited above. In this connection, it is to inform you that the building/premises was inspected by the officer concerned of this department on 23/06/2026 in the presence of Sh. Virender Singh to check the shortcomings already issued by this department vide letter No. F6/DFS/MS/GH/2024/SZ/672 dated 05/11/2024. (copy enclosed)


The Following shortcomings are still not complied.

1. Fire check doors found removed at some places.
2. CO detectors are provided but not functional.
3. Exit signages are found removed.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

Encl: as above


(A.K. Malik)
Chief Fire Officer

Copy to-

1. Owner/Occupied-, M/s JPM Majestic Guest House. located at D-52, East of Kailash, New Delhi- 110065. (Online application-ID- 2026060908550 dated 10/06/2026).