

C98

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/GH/SZ/2026/ 639

Dated: 10/07/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding renewal of FSC from fire safety point of view in r/o M/s. The Grand Orion (A Unit of Strengthening India Pvt Ltd) located at A-60, GF, FF, SF, TF, Kailash Colony New Delhi- 110048.


Sir,

Please refer to your online application no. No. 2026060508248 dated-10/06/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 23/06/2026 in the presence of Sh. Sikender Yadav the following shortcomings were observed during inspection.

1. Fire-Aid Hose Reels are provided but non functional.
2. MOEFA is provided but non functional.
3. Automatic Sprinkler system and Internal Hydrant provided but non functional.
4. Terrace level pump capacity of 900 LPM is provided but non functional.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot consider at this stage. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


(A.K. Malik)
Chief Fire Officer
10/8/26

Copy To: -

1. The Owner/occupier, M/s. The Grand Orion (A Unit of Strengthening India Pvt Ltd) located at A-60, GF, FF, SF, TF, Kailash Colony New Delhi-110048. (Online application No. 2026060508248 dated-10/06/2026).