

026

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No F6/DFS/MS/2026/School/NZ/87

Dated: 01/07/2026

FIRE SAFETY CERTIFICATE

Certified that the D.A.V. Public School located at Pushpanjali Enclave, Pitampura, New Delhi – 110034, comprised of Ground + 03 Upper floors only was issued FSC by this department vide letter No F6/DFS/MS/School/WZ/2023/501 dated 24.07.2023. The premises was re-inspected by the officer concerned of this department on 17/06/2026 in the presence of Sh. Uma Shankar and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Act 2007 and Delhi Fire Service Rules 2010 and that the building/ premise is fit for occupancy class "Educational Building" Group-B, with effect from ...01/07/2026... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule, 40 & subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to the compliance of the conditions mentioned below.

Issued on ...01/07/2026..... at New Delhi, by


(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service
OR

Copy to :-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.
2. The Principal, D.A.V. Public School located at Pushpanjali Enclave, Pitampura, New Delhi – 110034

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : D.A.V. Public School located at Pushpanjali Enclave, Pitampura, Delhi-110034
2. Type of Occupancy : Educational
3. Building Comprised of : Ground plus Three upper floors.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/School/WZ/2023/501 Dated 24/07/2023
6. Fire Safety directives letter No : DOE Circular 3298-3398 Dated 01/03/2011/ NBC Part-IV
7. Date of inspection : 17/06/2026
8. Name of Inspecting Officer : R.K.Sinha, ADO (Shalimar Bagh)
9. Name and designation of officers
From the building side : Sh. Uma Shankar
10. Year of Construction : 1993
11. Applicant's letter No. : Online ID No. 52026052503157

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE/ As per Inspection report dated 12.07.2023	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	4.05 m to 4.40 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	3 x 1.5 m each	2 x 1.4 m, 1 x 1.53 m, 1 x 1.35 m	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	18 Nos.	Provided	MR
	• Types	ABC/ Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02	03 Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA

	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided	MR
	• Number of hydrants per floor	NA	04 Provided (at G.F.)	MR
	• Hose Box	NA	04 Provided (at G.F.)	MR
m	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm & 180 lpm Provided	MR
	➤ Head of the pump	40 mts each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			

19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under D.O.E. circular dated 17.01.2005, it is **recommended to renew** the fire safety certificate issued vide letter no F6/DFS/MS/School/WZ/2023/501 dated 24/07/2023 under Rule 37 of the Delhi Fire Service Rules, 2010.

(Signature)
ADO/Shalimar Bagh
18/6/26

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/Shalimar Bagh

Do (Central North Division)
(Signature)
22/6

CFO/NZ
(Signature)
23/6/26

Principal Director
(Signature)

DAV Public School
Pitampura
Pitampura

CFO to Issue

(Signature)
23/6/26

CFO (EC)
(Signature)

(Signature)
24/6/26

ADO/SB
San. PT letter in progress for San. files
(Signature)
24/6/26