



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No. F6/DFS/MS/WZ/School/2026/ 609

Dated: 02/07/2026

To,
The Principal,
G.R.M. Public School,
Ranhola, Akash Vihar, Najafgarh Road,
New Delhi-110041.

Sub: Renewal of Fire Safety Certificate in r/o G.R.M. Public School, located at Ranhola, Akash Vihar, Najafgarh Road, New Delhi-110041.

Sir,

Kindly refer to your online application Id-52026060403370, received in this department on the subject cited above. In this connection, it is informed you that the building was visited by officer concerned of this department on dated 15.05.2026 in the presence of Sh. Hari Shokeen. During the inspection, it has been observed that the shortcoming already issued vide this department vide letter no. 854 dated 27.11.2025 is not yet rectified (Copy enclosed).

Therefore, you are advised to submit point-wise compliance of shortcomings already issued vide this department letter dated 27.11.2025 for further consideration in this matter.

Yours Faithfully

Encl: As above.

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-47



No: F.6/DFS/MS/2025/WZ/ 854

Dated: 27/11/2025

To,

The Principal,
G.R. M. Public School,
Ranhola, Akash Vihar, ,
Najafgarh Road, New Delhi-110041.

Sub:- Renewal of Fire Safety Certificate in respect of G.R. M. Public School
located at Ranhola, Akash Vihar, Najafgarh Road, New Delhi- 110041.

Sir,


This has reference to your Form J received through outdoor diary no. 7734 dated 03/11/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 17.11.2025 to see the compliance of the requisite fire safety measures. Smt. Sunita Shokeen was present at the time of inspection.

During the course of inspection it was observed that previously the FSC was issued for two building blocks of Ground plus two upper floors but later as per letter of even no. 10 dated 11/01/2024, name of one building block was changed to Nihal Institute of Management and Professional Studies and now the school is running in single block of Ground and two upper floors only. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels nozzle found missing.
2. Terrace level pump not found in auto mode.
3. Empty overhead tank of 5000 ltrs capacity found provided against the required capacity of 10,000 ltrs.
4. Exit signages found removed at some places.


You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully


27/11/25

(S.K. Dua)

Dy. Chief Fire Officer
West Zone



Copy to :-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

upers a
03/12/25

upers
04.12.25