

C-155

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/SZ/2026/ 635
To,

Dated: 07/07/2026

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o M/s Kamla Type of Machine Pvt. Ltd. Located at D-185, Okhla Industrial Area Phase-I, New Delhi-110020.


Sir,

Please refer to your online application no. No. 2026060408084 dated-05/06/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 23/06/2026 in the presence of Sh. Rajesh Yadav the following shortcomings were observed during inspection.

1. Fire Check doors found removed.
2. Smoke management system is provided but non functional.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot consider at this stage. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier r/o M/s Kamla Type of Machine Pvt. Ltd. Located at D-185, Okhla Industrial Area Phase-I, New Delhi-110020. (Online application No. 20260260408084 dated-05/06/2026).