



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52025120800325

Dated: 12-01-2026

SHORTCOMING(S)

With reference to your application ID **52025120800325** dated **12-01-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **North MCD Co-ed School** at **Rouse Avenue, DDU Marg, New Delhi** from fire safety point of view in presence of **Sh. Bachan Singh, Principal** on dated **31/12/2025** During the course of inspection following observations were made:-

1. Terrace pump provided but found non-functional.
2. Hose reel provided but found non-functional.
3. Exit signage found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Dy.Chief Fire Officer

Copy to:-

1. BACHAN SINGH , MCD CO-ED SCHOOL, DDU MARG, NEAR BJP HEADQUATER, NEW DELHI, 110002
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.