



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52025121500584

Dated: 06-02-2026

SHORTCOMING(S)

With reference to your application ID **52025121500584** dated **06-02-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Suraj Bhan DAV Public School** at **Vasant Vihar, New Delhi-110057** from fire safety point of view in presence of **Gargi Chhabra** on dated **16/01/2026** During the course of inspection following observations were made:-

1. First Aid hose reel provided but nonfunctional
2. Pump provided but not functional.
3. Tank found empty.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-

1. GARGI CHHABRA , 188 KOHAT ENCLAVE , VTC, PITAMPURA , DELHI , 110034
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.