



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52025123001039

Dated: 10-03-2026

SHORTCOMING(S)

With reference to your application ID **52025123001039** dated **10-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Suneja Tower - I** at **Plot No. 07, District Centre, Janakpuri, New Delhi-110058** from fire safety point of view in presence of **Mr. Nasim (Secretary)** on dated **05/03/2026** During the course of inspection following observations were made:-

Shortcomings observed are as below;

1. Fire check door found removed from main staircase.
2. First-Aid Hose reel provided found non-functional.
3. Automatic fire detectors found non-functional.
4. Automatic sprinklers found removed in basement floor.
5. Internal hydrants & hose-box found non-functional
6. Fire pumps were not on auto mode.
7. Exit signage found removed at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-

1. ANIL SAWHNI , A1/238, 0, JANAK PURI, NEW DELHI, 110058
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.