



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52025123101043

Dated: 26-02-2026

SHORTCOMING(S)

With reference to your application ID **52025123101043** dated **26-02-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **NEEV Pre to Primary School** at **211-212, Varun Farm Complex, Gate No.-2, Gaushala Road, Satbari, Chhattarpur, New Delhi-110074** from fire safety point of view in presence of **Ms. Deepika** on dated **06/02/2026** During the course of inspection following observations were made:-

1. Hose reel found non functional.
2. Sprinkler system found non functional in basement.
3. Terrace pump found non functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-

1. Deepika Sharma , E - 118, I Floor, Saket, New Delhi, 110017
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.