



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026012300536

Dated: 25-03-2026

SHORTCOMING(S)

With reference to your application ID **52026012300536** dated **25-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Hindon C.G.H.S. Limited** at **Plot no. 25, Vasundhara Enclave, Delhi-96.** from fire safety point of view in presence of **Secretary** on dated **17/03/2026** During the course of inspection following observations were made:-

- 1.All water based Systems like Fire Pumps, Hose Reels, Internal and Yard Hydrants, are non- functional.
- 2.Manual Operated Electrical Fire Alarm system(MOEFA) found non functional.
- 3.Exit signages found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Dy.Chief Fire Officer

Copy to:-

1. Rajender Kumar , C-706, HINDON CGHS LTD, Vasundhara Enclave, , Delhi -110096, 110096
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.