



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026020400823

Dated: 06-03-2026

SHORTCOMING(S)

With reference to your application ID **52026020400823** dated **06-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Rising Star Junior School** at **Sector-10, Dwarka, New Delhi-110075** from fire safety point of view in presence of **Ms. Monika** on dated **23/02/2026** During the course of inspection following observations were made:-

1. First aid hose reel found non-functional
2. Terrace level fire pumps not found automatic in operation.
3. Overhead water storage exclusively for firefighting found used for domestic purposes.
4. Basement floor is used for school activities. Class room found constructed and alternate staircase is accessible through class room.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-

1. Rising Stars Junior School , RisingStarsJuniorSchool, Sector-10, Dwarka, New Delhi, 110075
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.