GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026020900924 **Dated: 24-02-2026**

SHORTCOMING(S)

With reference to your application ID **52026020900924** dated **24-02-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **St. Johns School** at **Institutional Area, Pocket-III, Mayur Vihar, Delhi - 110091.** from fire safety point of view in presence of **Mr. Jerish John (Admin.)** on dated **10/02/2026** During the course of inspection following observations were made:-

1. There is significant addition/ alteration in the building. The approved plan of the building in 1: 100 scale along with floor wise occupancy may be submitted to this department.
2. Two Staircases of minimum width of 1.5 m leading from Ground to terrace shall be provided in each block else both the blocks must be linked through the continuous passage of 1.5 meters width connecting both the staircases at every floor.
3. The width of the corridor shall not be less then 1.5 m in any block.
4. Hose reel system must be provided in each block at each floor level.
5. Terrace Tank of 10 KL with terrace fire pump of 450 LPM and 40 meters head must be provided.
6. Exit signages must be provided.
7. Standby Power supply for all Fire Safety Installations is required to be provided.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Dy.Chief Fire Officer

Copy to:-
1. St Johns Model School , St Johns Model School, Institutional Area, Pocket 3, Mayur Vihar Phase 1, 110091
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.