



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026022301173

Dated: 24-03-2026

SHORTCOMING(S)

With reference to your application ID **52026022301173** dated **24-03-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Lancer's Convent Sr. Sec. School** at **Sector-14, Rohini, Delhi-110085**. from fire safety point of view in presence of **Sh. Lalit Solanki (Transport Manager)** on dated **10/03/2026**

During the course of inspection following observations were made:-

1. Exhaust fan system found removed in basement.
2. Hose reel hose is provided But Damaged Condition.
3. MOEFA system is provided but not functional.
4. Public address system is but not functional.
5. Sprinkles system is provided in basement but short in no's.
6. Internal hydrant systems is provided but damaged condition & some hoses found also damaged condition.
7. Yard hydrants is provided but damaged condition.
8. D.G set is provided but not functional & all pumps not in auto mode.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Dy.Chief Fire Officer

Copy to:-

1. HEMA SANGAL , C-8/ 322, Sector-8, Rohini, Delhi, 110085
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.