GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026030601447 **Dated: 07-04-2026**

SHORTCOMING(S)

With reference to your application ID **52026030601447** dated **07-04-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sawhney Electronics Pvt. Ltd.** at **Plot No. A-26/1 Mohan Co-operative Industrial Area/Estate, Mathura Road, New Delhi - 110044** from fire safety point of view in presence of **Mr. Sibhash Chander** on dated **25/03/2026** During the course of inspection following observations were made:-

1.Smoke Management System provided but not functional.
2.Automatic Fire Detection and Alarming System provided but not functional.
3.MOEFA provided but not functional.
4.Public Address System provided but not functional.
5.Exit & floors Signage's not provided in strategic location in the building.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Dy.Chief Fire Officer

Copy to:-
1. SUBHASH CHANDER , 216-217, Basant Evenue, Amritsar-1st, Amritsar, 143001
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.