



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026032101762

Dated: 16-04-2026

SHORTCOMING(S)

With reference to your application ID **52026032101762** dated **16-04-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Swati Public School** at **D-1/41, New Kondli, Mayur Vihar Phase-III, Delhi-96** from fire safety point of view in presence of **Sh. Anil Sharma, Owner** on dated **07/04/2026** During the course of inspection following observations were made:-

1. Basement is not provided with an alternate staircase of minimum width of 0.75 m.
2. Hose reel not extended to the basement.
3. All water based Systems like Hose Reels & Fire Pumps are non- functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Dy.Chief Fire Officer

Copy to:-

1. Swati Public school , D1/41 NEW KONDLI PHASE 3 , Delhi 110096, New Kondli , EAST DELHI , 110096
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.