



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026041802332

Dated: 08-09-2026

SHORTCOMING(S)

With reference to your application ID **52026041802332** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **VSPK International School** at **Sector-13, Rohini, New delhi-110085**. from fire safety point of view in presence of **Sh. Sandeep Kumar, Caretaker** on dated **10/08/2026** During the course of inspection following observations were made:-

1. Hose reel hose is provided but not functional and some hose reel damaged condition.
2. Automatic sprinkler system is provided but not functional.
3. Internal hydrants is provided but not functional.
4. Yard hydrants is provided but not functional.
5. Ground level fire pumps capacity of 2280 LPM, Diesel engine fire driven pump capacity of 2280 LPM and jockey pump capacity of 180 LPM is provided but not functional
6. Terrace level fire pump capacity of 900 lpm is provided but not functional and not in auto mode.
7. Overhead terrace tank capacity of 25,000 ltr is provided but domestic used, fire fighting tank must be dedicated for fire fighting purpose only.
8. Exits and floor signages found removed at strategical location in the school premises.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. VSPK INTERNATIONAL SCHOOL, VSPK INTERNATIONAL SCHOOL, SECTOR - 13, ROHINI, DELHI, 110085
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.