



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026052103074

Dated: 08-09-2026

SHORTCOMING(S)

With reference to your application ID **52026052103074** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **SARVODAYA KANYA VIDYALAYA /SARVODAYA BAL VIDYALAYA** at **NOOR NAGAR JAMIA NAGAR Okhla New Delhi** from fire safety point of view in presence of **Suresh Kumar vice Principal** on dated **19/08/2026** During the course of inspection following observations were made:-

- 1.Fire extinguishers are provided but no in adequate condition.
- 2.First aid hose reels are Provided but not functional.
- 3.Terrace level fire pump capacity of 2X 450 LPM are provided but not functional.
- 4.Over head tank capacity of 10,000ltrs. Is provided but found empty.
- 5.Exit signages are found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. MUDASSIR JAHAN , SKV NOOR NAGAR, JAMAI NAGAR, OKHLA, DELHI, 110025
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.