



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026061003579

Dated: 07-10-2026

SHORTCOMING(S)

With reference to your application ID **52026061003579** dated **07-10-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Link House C.G.H.S. Ltd.** at **Plot No. 18 Patparganj, I.P. Extension, Delhi-110092** from fire safety point of view in presence of **Secretary** on dated **11/09/2026** During the course of inspection following observations were made:-

1. First Aid hose reels are not functional.
2. Down-comers are not functional.
3. MOEFA not functional.
4. PA System not functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. PREM SHANKER , 605 LINK APARTMENT, PLOT NO. 18, I P EXTENSION, PATARGANJ, EAST DELHI, 110092
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.