



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026072804732

Dated: 08-09-2026

SHORTCOMING(S)

With reference to your application ID **52026072804732** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M/s Plot No. H-24,** at **Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041** from fire safety point of view in presence of **Mr. Gopal Wadhwa** on dated **06/08/2026**

During the course of inspection following observations were made:-

- 1.The width of one staircase was found reduced due to the addition of a sliding ramp/stair.
- 2.Fire check doors is found removed in basement.
- 3.The smoke management system was found removed in the basement.
- 4.Only 01 number of First Aid Hose Reel has been provided against the required 02 numbers per floor; moreover, the installed hose reel was found non-functional at the time of inspection.
- 5.The fire pump and tank were found shifted to the terrace; however, they were not accessible and therefore could not be inspected.
- 6.The underground fire tank was found removed at the time of inspection.
- 7.Exit signages were found removed at some locations.
- 8.The mezzanine floor was found to have been extended over the entire covered area

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. Amit Ranchal , H 149 , Ashok Vihar , Phase-1, Delhi, 110052
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.