



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-160

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/ECN/2026/616

Dated: 04/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Superb Guest house/ 2325-2326, Chuna Mandi, Paharganj, New Delhi-110055.

Sir,

Please refer your online application ID No. 2026060307931 dated 05/06/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 22/06/2026 in the presence of Sh. Gopal Khanna, Owner and following shortcomings were observed: -

1. Smoke Management System found removed in building.
2. Further, staircases shall be provided with Hand Railing.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

o/c B8

Copy to: -

1. The Manager, M/s Superb Guest house/ 2325-2326, Chuna Mandi, Paharganj, New Delhi-110055.