



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 603

Dated: - 02/07/2026

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya (School ID-1413070),
Sector-16, Pocket-A, Rohini, Delhi-110085.

Sub.: - Regarding renewal of Fire Safety Certificate in respect Govt. Sarvodaya Kanya Vidyalaya (School ID-1413070), located at Sector-16, Pocket-A, Rohini, Delhi-110085.

Sir,

This has reference to DFS online portal application no. 52026060103299 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 15/06/2026 in the presence of Ms. Bhawana (Principal). During inspection, it was observed that the above said building is comprised of ground + 03 upper floors. After inspection, the following shortcomings were observed: -

1. Fire extinguishers found empty.
2. First-Aid Hose Reel Hose found non-functional and nozzles also found removed.
3. Fire pump found non-functional.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.