

c/491

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI – 110001.**

NO. F.6/DFS /MS/NDZ/2025/ 102

Dated: /0 03/2025

To,

Sh. Lt. Col Deependra Mishra,  
General Manager (ITPO),  
ITPO, Pragati Maidan,  
New Delhi.

**Sub: Application for renewal of Fire Safety Certificate in respect of the building hall A2 to A5 at Bharat Mandapam, Mathura Road, Pragati Maidan, New Delhi.**

Sir,

This has a reference to your letter no. GM(works)/fire NOC/Feb 2025 /DM/1 dated 21.02.2025 & received DFS diary no. 12825 dated 24.02.2025, on the subject cited above. In this connection it is to inform you that the site was inspected by ADO/CC & DO/CD in presence of **Sh. Amit, fire officer & Vikas Singh, ITPO** and other representative of Shapoorji on dated 27.02.2025 and the following shortcomings were still not complied :-

1. Smoke curtain were found nonoperational to achieve the complete compartmentation of halls.
2. Glass of Fire check doors at some places found broken and shafts (horizontal and vertically) are also not sealed properly.
3. Water curtain in basement found ineffective.

Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department at the earliest. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)  
**DIRECTOR**  
**Delhi Fire Service**

Copy to:

1. Sh. Vikas Kumar Singh GM (Security), ITPO, Pragati Maidan, New Delhi.