

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/Banquet/2025/SZ/||

Dated: - 18/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **M/s A-1 Banquets**, running at ground & first floor only in a building comprised of basement, ground plus two upper floors (Basement & second floor are closed), located at Plot No. A-1, Naraina Industrial Area, Phase-1, New Delhi- 110028. The banquet hall building was inspected by the officer concerned of this department on dated 11.03.2025, in the presence of Mr. Naresh Bansal, and found that the banquet hall building have complied with the fire prevention and fire safety requirements in accordance with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class "D" "Assembly Building" (**for ground & first floor only**) w.e.f. 18/03/2025 for a period of **three** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 18/03/2025 at New Delhi.

(Atul Garg)
 Director
 Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Delhi: for information regarding use of basement and to ensure the occupancy as detailed above and deviation, if any.
2. **Online application Id 2025021802049 dated 19.02.2025.**

Conditions for validity of Fire Safety Certificate: -

1. **This NOC is valid only for ground & first floor.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/24

INSPECTION REPORT

1. Name & address of the building : M/s. A-1 Banquets at A-1, Naraina Industrial Area, Phase-I New Delhi- 110028.
2. Building comprised of : B, G+2 upper floors, Banquet Hall running at Ground and 1st floor only (Basement & 2nd floor are closed)
3. Type of Occupancy : Assembly D-3
4. Type of Case : New Case
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 11.03.2025
8. Name of Inspecting Officer : R.K. Yadav, ADO (JKP)
9. Name and designation of officers
From the building side : Mr. Naresh Bansal
10. Year of Construction : Before- 2010
11. Applicant's letter No. : Online application 2025021802049 dated 19.02.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible (06 mtrs.) 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s N/A	03 No's N/A	MR (Basement Closed)
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	2.0 & 1.50 M N/A	2.0 m (2 no's) & 0.90 M N/A	MR (Basement Closed)
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.0 m each	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	MR N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floor 	N/A Required	N/A Natural Ventilation	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers on each floor Types IS marking 	20 no.'s ABC/CO ₂ /W CO ₂ type ISI marked	20 no.'s Provided Provided	MR MR MR

N/35

6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 no's	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors Smoke/Heat	Required	Provided	MR
	• Location of Main Panel	Required	GF	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	At GF	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box	One	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM & 180 LPM	MR
	➤ Head of the pump	40 mtrs	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	25,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR


Provision of Lifts.				
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010.

Note: - As per undertaking submitted by Banquet Hall management (placed at C-101) the Banquet Hall running at ground & first floor only in a building comprised of Basement, ground plus two upper floors. The Basement area is 35 Sq m. which is currently closed & unused. 2nd floor of the said premises is closed and not use for any purpose.

Accordingly, DFA, is put up for approval & signature please.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (South West)



2/3/25

CFO/



13/3/2025

Director



