

C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/BNQT/SZ/2026/ 681

Dated: 15/07/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o. M/s. Aahil villa Banquet Private Limited, Located at Property No. Ground Floor, G-57, KH No. 537, Madanpur Khadar Extn. -II, Sarita Vihar, New Delhi-110076.


Sir,

Please refer to your online application no. No.2026052807633 dated 29/05/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 15/06/2026 in the presence of Mr. Mohd. Yamin. During inspection, the following shortcomings were observed.

1. MOEFA is provided but not functional.
2. Main Firepump 900 lpm is provided but not on auto mode.
3. Exit signages are not provided.

In view of above Shortcomings, the application for issuance of fire safety certificate is cannot considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


(A.K. Malik)
Chief Fire Officer

Copy to: -

1. The authorized signatory, M/sAahil villa Banquet Private Limited, Located at Property No. Ground Floor, G-57, KH No. 537, Madanpur Khadar Extn. -II, Sarita Vihar, New Delhi-110076. (Online application No. 2026052807633 dated 29/05/2026).