



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

2/30

No. F6/DFS/MS/Hospital/NDZ/2025/154

Dated 09/04/2025

To,

The Administration Head,
Aakash Healthcare Super Speciality Hospital Pvt. Ltd.,
Sector-3, Dwarka, New Delhi.

Subject: - Regarding grant of Fire Safety Certificate in r/o Aakash Healthcare Super Speciality Hospital Pvt. Ltd. located at Sector-3, Dwarka, New Delhi.

Sir,

This has a reference to online Id No- DW3/0024/2021/OCC dated 19/03/2025, on the subject cited above. In this connection, it is to inform you that the additional building/floor have been inspected by the officers concerned of this department alongwith representatives of DDA, J.E (Bldg.) L&I Mr. Surya, jointly on 03/04/2025 and during inspection following shortcomings have been observed :

1. Door closers found removed from some fire check doors.
2. Compartmentation at upper levels has not been provided.
3. Electrical shafts are not sealed at each level.
4. Detectors and sprinklers need to be extended in left out areas.
5. Inspection ladder for overhead water tank not provided.
6. Pressurization of lift lobbies is not effective/partially provided.
7. Only 02 fire towers have been made against the requirement of 03 fire towers.
8. Fire towers have not been extended upto terrace level.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Joint Director(Building), DDA, Vikas Sadan, INA, New Delhi.
2. The Director, General of Health Service, F-17, Karkardooma Delhi-110032.