

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/Educational/2026/SZ/ 55

Dated: 28/04/2026

FIRE SAFETY CERTIFICATE

Certified that the Aakash Education Services Limited at Plot No. 59, Sector- 12, Dwarka, New Delhi- 110078, comprised of basement (vacant), ground plus three upper floors (Coaching Centre), owned/occupied by M/s. Aakash Educational Services Limited, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on dated 13.04.2026 in the presence of Mr. Gaurav Kumar, and found that the building is fit for occupancy class "Educational Building" with effect from 28/04/2026 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 28/04/2026 at New Delhi by.


 27/4/26
 (A.K. Malik)
 Chief Fire Officer
 South Zone

Copy to:-

1. The Owner/Occupier, Plot No. 59, Sector- 12, Dwarka, New Delhi- 110078.
 2. Executive Engineer (Bldg.), MCD, Civic Centre, Minto Road, New Delhi.
- : - for information and to check the use of basement.

Conditions for validity of Fire Safety Certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. Basement shall be used as per the building bye laws and use of the basement will only be allowed after permission from MCD. Presently basement is vacant and not in use.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Aakash Education Services Limited (AESL) at Plot No. 59, Sector-12, Dwarka, New Delhi- 110078.
2. Building is comprised of : Basement (Vacant), Ground plus three upper floors (Coaching Centre)
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous FSC : Nil
6. Fire Safety directives letter no. : Nil
7. Date of Inspection : 13.04.2026
8. Name of the Inspecting officers : R.K. Yadav, ADO (DWK)
9. Name and designation of Officer from the building side : Mr. Gaurav Kumar
10. Year of Construction : 2024-25
11. Applicant's letter No : MCD Request ID- 70000313

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per NBC U/R33-2016	Provided at Site	Remarks
1	Access to building			
	• Road width	06 m	20 m	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 Nos.	2 Nos.	MR
	• Basement	2 Nos.	2 Nos.	MR
	b. Width of Staircases			
	• Upper Floor	1.5 M each	Provided	MR
	• Basement	1.5 M each	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 nos.	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1.20 m	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	15 Nos.	20 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

N/7


6	First-aid-Hose Reels.			
	Total numbers of each floor	1 Nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	Provided	N/A
	• Location of main panel	N/A	Provided at GF	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	Provided	N/A
	• Hooter's location	N/A	Provided at each floor	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement/Stilt	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 Nos.	Provided	MR
	• Hose Box	01Nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level each block			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 Ltrs	15,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	Required	LT & HT panel provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - The building comprised of basement, ground plus three upper floors, using basement is vacant and not in use, ground floor having office space & 01 class room, 1st, 2nd & 3rd floor each having 04 classrooms.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule, 2010.


Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation:- ADO (DWK)

DO (SW)

18/4/26
RAJINDER ARWAL
CFO (SZ)


21/4/26
A.K. MALIK
Principal Director

CFO to S.O. No. 1
22/04/26


23/4/26
A.K. MALIK
DO (SW)

CFO (SZ)

23/4

ADO - Jura