



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2025/WZ/ 626

Dated: 11/8/25

To,

The Principal,
Aaryan's Kids World School,
Kuldeep Akhada, Near CPJ College,
Narela, Delhi-110040.

Sub: Regarding issuance of Fire Safety Certificate in r/o Aaryan's Kids World School located at Kuldeep Akhada, Near CPJ College, Narela, Delhi- 110040.

Sir,

This has reference to your application no. Nil received through outdoor diary no. 2444 dated 04.06.2025 on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department on 04.07.2025 to ascertain the availability and operability of the fire prevention and fire safety measure, Sh. Kuldeep Singh was present at the time of inspection. During the course of visit it was observed that building is comprised of Basement and Ground Floor but school is running on ground floor only.

Your request for issuance of FSC is rejected due to the following **shortcoming**:-

1. RCC road is required for the access of fire engines instead of dirt/ kaccha road.
2. Gate width found 3 m against the required width of 4.5 m.

You are advised to rectify the above-mentioned **shortcomings** under intimation to this department.

Yours Faithfully


5/8/25
(Virendra Singh)
Chief Fire Officer
BLN

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.