



सत्यमेव जयते
625

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2025/NDZ/ 734

Dated 17/09/2025

To,

The Manager,
Abhinav Bharti Model School,
E-Block, Subhash Vihar, North Ghonda,
Delhi-110053.

Sub:- Regarding renewal of Fire Safety Certificate r/o Abhinav Bharti Model School located at E-Block, Subhash Vihar, North Ghonda, Delhi-110053.

Sir,

With reference to your letter no. abhinavbhartibhawan@gmail.com dated 02/07/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on dated 30/08/2025 of the above-mentioned School from fire safety point of view in presence of the Sh. Pramod Kumar. The building comprised of Ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. First Aid house reels provided but not functional.
2. Down comers provided but not functional.
3. Terrace pump provided but not functional.
4. Exit Signages are not provided.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above-mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully,

10 1619
(VIRENDRA SINGH)
CHIEF FIRE OFFICER

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar, Delhi- 110053