



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/ 652

Dated: 18/08/2025

To

Ms. Vandana Kumari,
(Vice Principal)
Abhinav Global School,
Sector-13, Dwarka,
New Delhi-110078

Sub: Renewal of Fire Safety Certificate in r/o Abhinav Global School located at Sector-13, Dwarka, New Delhi-110078

Sir,

Please refer to your letter No. AGS/2025-26/795 dated 19/06/2025, received in this department vide outdoor diary No. 2923 dated 20/06/2025. In this connection, it is to inform you that the premise was inspected by the concerned officers of this department on 17/07/2025 in the presence of Sh. Jatin Gola (Administrator). During course of inspection, it was observed that school activities are also running at 3rd floor of the building. Whereas, the school management did not fully comply with shortcomings issued by this office vide letter No. F6/DFS/MS/School/2018/SZ/1676 dated 25/04/2018. **Further, the shortcomings observed are as below.**

1. Six-meter-wide internal motorable road 45-ton load bearing all around the building for free movement of fire vehicles found encroached/blocked.
2. Hose-reel hose and internal hydrant system found non-functional.
3. Terrace fire pump was not on auto mode.
4. Exit signage found removed at some places.
5. Smoke/Fire Check Door have not been provided and staircase are required to be separated at ground level.

In view of above, application for **renewal of fire safety certificate cannot be considered at this stage**. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
17/8/25

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.