

c184

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/NDZ/2025/*College/68*

Dated: 09.06.2025

To,

Ms. Renu Khanna,
Multistoried Academic Tower,
Zakir Husain Delhi College,
Jawahar Lal Nehru Marg, New Delhi.

Sub: Regarding issuance of Fire Safety Certificate in r/o Multistoried Academic Tower at Zakir Husain Delhi College, located at Jawahar Lal Nehru Marg, New Delhi.

Sir,

This has reference to Mail id no.<renukhanna.architect@gmail.com> dated 20.05.2025, on the subject cited above. In In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 04-06-2025 in the presence of Mr. Sourav Attendent & Deepak Choudhary, and observed that shortcomings issued earlier vide letter no. F6/DFS/MS/NDZ/2024/College/86 dated 07/05/2024 (copy enclosed) have not been completely complied so far.

Hence, Fire Safety Certificate (FSC) cannot be renewed at this stage. Therefore, you are requested to rectify all the shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

Encl: As above.

[Signature]
8/6/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
[Initials]

Copy to:

The Commissioner, MCD, Civic Center, New, New Delhi.

c-133
c-110

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2024/College/ 86

Dated:-07/05/2024

To

Prof. Narendra Singh (Principal),
Zakir Husain Delhi College (University of Delhi),
Jawahar Lal Nehru Marg, New Delhi-110002.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o Multistoried Academic Tower at Zakir Husain Delhi College Jawahar Lal Nehru Marg, New Delhi.

Sir,

This has a reference to your letter no. Nil dated 01.04.2024, on the subject cited above. In this regard, this is to inform you that the site was inspected by the officers concerned of this department on 29/04/2024 in the presence of Mr. Arpan Rites (AM) from building side and following shortcomings were observed:

1. 06 meter all around road for fire tender movement found obstructed due to branches of trees fall on the way.
2. Pressurization of staircase, lift lobby & shaft found nonfunctional.
3. Hose reel & hydrant found nonfunctional.
4. Smoke management system found nonfunctional.
5. PA system & MOEFA found nonfunctional.
6. Diesel Pump found nonfunctional and pumps also not in auto mode provision.

In view of above, the case is rejected with a request to rectify the above shortcomings immediately. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)

DIRECTOR

01123414000

Copy to :

1. The Commissioner, MCD, Civic Center, New Delhi.