



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

75
 आज़ादी का
 अमृत महोत्सव

No: F6/DFS/MS/Hosp/WZ/2025/ 190

Dated: 17/04/2025

FIRE SAFETY CERTIFICATE

Certified that the Acharya Bhikshu Hospital, located at Moti Nagar, New Delhi – 110015, comprised of Basement + Ground + 3 Upper Floors (100 Bedded), was issued FSC by this department vide Letter no. F6/DFS/MS/Hosp/WZ/2022/98 dated 07/03/2022. The premises was re-inspected by the officer concerned of this department on 09/04/2025 in the presence of Sh. Raj Kumar Meena (JE) (E) and found that the Fire prevention and fire safety arrangements provided in the premises found in good working condition and the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group C (Institutional) with effect from 17/04/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/04/2025 at New Delhi.

Arul Garg
 Director

Copy to:-

1. The Medical Superintendent, Acharya Bhikshu Hospital, located at Moti Nagar, New Delhi – 110015.
2. Assistant Engineer (E)-5, PWD HMESD South West, Acharya Bhikshu Hospital, Moti Nagar New Delhi-110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Acharya Bikshu Hospital, Moti Nagar, New Delhi- 110015
2. Type of Occupancy : Institutional (Hospital)
3. Type of Case : Renewal (Basement + Ground + 3 Upper Floors)
4. Details of previous NOC : F6/DFS/MS/Hosp/WZ/2022/98 dated 07/03/2022
5. Fire Safety directives letter No : F6/DFS/MS/BP/Hospital/2001/193 dated 29/01/2001
6. Date of inspection : 9/04/2025
7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Sh. Raj Kumar Meena (JE) (E)
9. Year of Construction : NA
10. Applicant's letter No. : Letter No. 24(09)/AE(E)-III/PWD HMEDSW/2024/2025/22 dated 07/03/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	11.5 mts Provided	MR
	• Gate width	5 mts	Provided	MR
	• Width of internal road	Required	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	06 stairs + 01 ramp	Provided	MR
	• Basements	06	Provided	MR
	b. Width of staircases			
	• Upper Floors	2 mts	4 x190 cm, 1x140cm, 1x150 cm & ramp 255 cm	MR (old case)
	• Basements	2 mts	4 x190 cm, 1x140cm, 1x150 cm & ramp 255 cm	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	02	Provided	MR
	f. Width of Corridor	Required	280cm Provided	MR
	g. Door Size	Required	197cm Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Open able window provided	MR
5	Fire Extinguishers			
	• Total numbers	50 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04 on each floor	Provided	MR
		30 mts	Provided	MR
		5 mm	Provided	MR
7	Automatic fire detection and alarming system.			MR
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required		
10	Automatic Sprinkler System.			MR
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants			MR
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		03	Provided	MR
		Required	Provided	MR
12	Yard Hydrants.			MR
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required	Provided	MR
		Required	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	2850 LPM	Provided	MR
		60 mts	Provided	MR
		02	Provided	MR
		180 LPM	Provided	MR
		60 mts	Provided	MR
		2850 mts	Provided	MR
		60 mts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	2,00,000 ltr	Provided	
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		30,000 ltr	Provided	MR
	Exit Signage.	Required	Provided	MR
15			Provided	MR

24/86

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NR	Provided	NR
	• Pressurization of Lift lobby	NR	NR	NR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NR	NR	NR
	➤ Location	NR	NR	NR
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the NOC issued vide letter no. F6 F6/DFS/MS/Hosp/WZ/2022/98 dated 07/03/2022, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

12/ADO/MN
11/04/2025

DCFO (12)

Signature of the Inspecting officer.
Name: - Sarabjeet Singh
Designation: - ADO (MN)

DCFO/613-WR
Dated 11/04/2025

CFO/11/4/2025

Director
14/4/25

Agmt Sir F. T is put up for
your kind perusal & signature please. 18/4/2025
Director