

c/24



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2025/ 40

Dated: 17/01/2025

To

The Principal,
Adarsh Vidya Niketan,
L-1st, Gali No. 8/1-1508, Sagwan Farm,
Sangam Vihar, New Delhi-80.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Adarsh Vidya Niketan** located at **L-1st, Gali No. 8/1-1508, Sagwan Farm, Sangam Vihar, New Delhi-80.**

Sir,

With reference to the letter bearing outdoor diary no. 10532 dated 19.12.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 08.01.2025 in the presence of Mr. Manbir Singh (Manager) and following shortcomings were observed during the inspection.

1. Hose reel found non functional.
2. Fire pump having capacity 450 LPM & head 40 m has not been provided.
3. Overhand tank capacity of 10,000 ltrs has not been provided for fire fighting.
4. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISTT. South Sector-3, R.K. Puram, New Delhi-22.