

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No.F.6/DFS/MS/School/2025/NDZ/588

Dated: 02/05/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Adarsh Vidya Niketan Public School located at 25, Shiv Mandir Gali, Maujpur, Delhi-110053, comprised of ground plus one upper floor (one room at terrace has sealed) owned/occupied the Adarsh Vidya Niketan Public was issued FSC vide letter No. F.6/DFS/MS/School/2022/NDZ/57 dated 21/01/2022. The school building was re-inspected by the officer concerned of this department on 16/04/2025 in the presence of Sh. Pradeep Kumar Arora, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class 'Educational' (Group-B) with effect from 02/05/2025 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..... 02/05/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

1. The Principal,  
Adarsh Vidya Niketan Public School located at 25, Shiv Mandir Gali, Maujpur, Delhi-110053.
2. The Director of Education,  
MCD, 419, Udyog Sadan, Patparganj Ind. Area, Delhi-110092.

**Conditions for the validity of Fire Safety Certificate**

1. FSC is valid for ground and first floor only. One room at the terrace which is sealed shall not be used for any purpose failing which FSC should be treated null and void.
2. All the means of escape shall be kept free of all type of obstruction all the time
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/13

1. Name & address of the building : Adarsh Vidya Niketan Public School  
25, Shiv Mandir Gali, Maujpur, Delhi-110053
2. Building is comprised of : Ground plus one upper floor  
(One room at terrace floor has sealed)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2022/NDZ/57 dated 21/01/2022
6. Fire Safety directive letter No. : Circular 262-362 dated 17/01/2005 issued by DoE
7. Date of Inspection : 16/04/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer  
from the building side : Sh. Pradeep Kumar Arora, Manager
10. Year of Construction : 1991
11. Applicant's letter No : Outdoor diary No 14884 Dated 21/03/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	06 mtr. N/A N/A	05 mtr. N/A N/A	MR (accepted earlier) N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases <ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul> B. Width of Staircases <ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basement</li> </ul> c. Protection of exits <ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul> d. No. of continuous staircases to terrace	01 nos. N/A 1.50 mtr N/A N/A N/A 01 no. 1.50 mtr 01 mtr.	02 nos. N/A 1.25 mtr & 0.95 mtr N/A N/A N/A 01 no. 1.50 mtr 01 mtr.	MR N/A MR N/A N/A N/A MR MR MR
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire rating of shaft door</li> <li>Water curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floor</li> </ul>	N/A N/A	N/A N/A	N/A N/A

R 013

4/14


05.	Fire Extinguishers			
	• Total numbers	04 nos.	06 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	220 lpm	220 lpm	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

2/18

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2,500 ltr	2,500 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A



The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Circular 262-362 dated 17/01/2005 issued by Director of Education, the FSC issued vide letter no. F.6/DFS/MS/School/2022/NDZ/57 dated 21/01/2022 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended..

  
Signature of the Inspecting Officer  
Name :- Deepak Kumar  
Designation :- ADO (Shd.)

~~DO (ED)~~ DFA please.

~~Sy CFO (NS2)~~   
King 16/04/2025

~~Director~~ C.F.O.   
21/4/2025  
 ADO/ST

P.T.O.