

c/o 8



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F.6/DFS/MS/WZ/2025/School/ 402

Dated: 15/05/2025

To,

The Principal,
Aadhar International School,
Pocket-B-1, Sector-4, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o Aadhar International School, Pocket-B-1, Sector-4, Rohini, Delhi-110085
(Previous name of school is Nursery School Building at Sector-4, Rohini, Delhi-110085).

Sir,

Kindly refer to letter received in this department through outdoor diary no. 12351 dated 11.02.2025 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **06.05.2025**, in presence of **Mr. Arun Kumar Diwadi** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Alternate staircase is not provided.
2. Hose reel provided but not functional.
3. Terrace Fire pump with capacity of 220 LPM not provided.
4. Over Head water captive tank of 2500 ltrs not provided.
5. The required exit signage are not provided.
6. Three side around the building found constructed temporary structure.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR
Ph: 011-23414000