0/10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

00

No: F.6/DFS/MS/School/2025/WZ/ 446

Dated: 26 | 05 | 2025

To.

The Principal, Aditya Bharti Public School, Sec. A-5, Pocket 8, Sunday Bazar Road, Narela, Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Aditya Bharti Public School located at Sec. A-5, Pocket 8, Sunday Bazar Road, Narela, Delhi- 110040.

Sir,

This has reference to your email id dated 17.04.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 14.05.2025 in presence of Smt. Krishna Sehrawat (Principal) to see the compliance of shortcomings issued vide letter no. F6/DFS/MS/School/2024/WZ/564 dated 28/08/2024.

Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Door width found 0.90 m against the required width of 1.20 m.

2. First aid hose reels found not provided.

3. Terrace level pump of 450 lpm discharge capacity found not provided.

4. Overhead tank of 10,000 ltrs capacity found not provided.

5. Exit signage's not provided.

6. Building plan in a scale of 1:100 not provided/ as built plan duly signed by Regt. Architect and owner are not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.