

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No.F.6/DFS/MS/School/WZ/2025 / 144

Dated: 11/02/2025

FIRE SAFETY CERTIFICATE

Certified that the **Adarsh Public School** located at **Sec-9, Rohini, Delhi-110085** comprised of Basement, ground & 02 upper floors (Basement-storage, school running at ground & 01 upper floor & second floor store house) owned/ occupied by **Adarsh Public School** was issued Fire Safety Certificated vide this office letter no. **F.6/DFS/MS/School/WZ/2021/1033** dated **21.12.2021** for (ground + one upper floor). The premises was re-inspected by the officer and observed that the school have deemed complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **22.01.2025** in the presence of **Mrs. Suvidha (In-charge)** and that the building/premises is fit for occupancy Group B Educational for basement, ground and first floor only with effect from 11/02/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 11/02/2025 at New Delhi

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to :-

- 1 The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
- 2 The Principal, Adarsh Public School, Sec-9, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building	Adarsh Public School located at Sec-9, Rohini, Delhi-110085.
2. Type of Occupancy	Educational
3. Comprised of building	Basement + Ground + 02 upper floors
4. Type of Case	Renewal (Basement- storage, school running at Ground + 01 upper floor & 2 nd floor store house)
5. Details of Previous NOC	F.6/DFS/MS/School/WZ/2021/1033 dated 21.12.2021.
6. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011.
7. Date of inspection	22.01.2025
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
9. Name and designation of officers From the building side	Mrs. Suvidha (In-charge)
10. Year of Construction	2010 & 2017
11. Applicant's letter No.	Online e-mail dated 02.01.2025


S. No	Minimum Standards on fire prevention and fire safety U/R 33	Rule 35 (6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	01nos.	01nos.	MR
	b. Width of staircases			
	• Upper Floor	1.5m	1.5m & (1.45m iron staircase)	MR (old case)
	• Basements	1.5m	1.68m	MR
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1m	1.03m	MR
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	30 a/c per hour	Exhaust fan	MR
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	a) Total numbers	12nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			

	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	a) Basement	Required	Provided	MR
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	Required	Provided	MR
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	900lpm	900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	15,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-

19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/School/WZ/2021/1033** dated **21.12.2021** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.


 Signature of the Inspecting Officer
 Name **Ajay Kumar Sharma**
 Designation **ADO(Rohini)**

D.B Mukherjee
 DO (NW)


 04/02/2025

Dy LEO (WZ) - M/R.



 6/2/2025


 7/2/25



FT letter to put up to kind
 perusal and signature please


 Director


 15/2/25

DCFO/... 934/162...
 Dated... 6/2/2025