

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI-110 001.**


Dated: 21/01/2026

No. F.6/DFS/MS/School/2026/SZ/ 14

**FIRE SAFETY CERTIFICATE**

Certified that the Aeron Public School located at Plot No. 153, Pocket- A, Sector- 8, Dwarka, New Delhi- 110077, school running at stilt (reception), upper ground and first floor only in a building comprised of basement, stilt upper ground floor plus three upper floors, basement, 2nd floor & 3rd floor is other's property, owned/occupied by Aeron Public School. The school building was inspected by the officer concerned of this department on dated 08.01.2026 in the presence of Ms. Bhavana Gupta, and found that the building/ premises (stilt, upper ground & 1<sup>st</sup> floor only) is fit for occupancy class B "Educational Building" with effect from 21/01/2026 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 21/01/2026 at New Delhi.

  
(A.K. Malik)

Dy. Chief Fire Officer  
South Zone

909

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.
2. The Principal, Aeron Public School located at Plot No. 153, Pocket- A, Sector- 8, Dwarka, New Delhi- 110077.
3. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.

: - for information regarding use of basement.

**Conditions for validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Presently basement is closed and not use for any purpose.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

# INSPECTION REPORT

1. Name & address of the building	Aeron Public School at Plot No. 153, Pocket-A, Sector- 08, Dwarka New Delhi- 110077		
2. Type of Occupancy	Educational		
3. Building comprised of	Basement (other's property), stilt (Reception), upper ground & 1 <sup>st</sup> floor (School), 2 <sup>nd</sup> & 3 <sup>rd</sup> floor (other's property)		
4. Type of Case	<b>New Case (school running at stilt, upper ground and 1<sup>st</sup> floor only)</b>		
5. Details of Previous NOC	N/A		
6. Fire Safety directives letter No	N/A		
7. Date of inspection	08.01.2026		
8. Name of Inspecting Officer	A.D.O. R.K.Yadav (DWK)		
9. Name and designation of officers From the building side	Ms. Bhavana Gupta		
10. Year of Construction	2022		
11. Applicant's letter No.	Nil, dated 16.12.2025		

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per NBC-4	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible 06 m 4.5 m N/A	06 m Directly accessible from road N/A	MR MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases <ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul> b. Width of staircases <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul> c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul> d. No. of continuous staircases to terrace           e. Width of Corridor           f. Door Size	02 No's N/A	03 No's N/A	MR N/A
		1.50 m each	1.50 m × 2 & 1.0 m × 1	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		02 No's	Provided	MR
		1.50 m	Provided	MR
		1.20 m	Provided	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A Required	N/A Natural ventilation	N/A MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Types</li> <li>• IS marking</li> </ul>	02 no.'s ABC/CO <sub>2</sub> type ISI marked	Provided Provided ISI marked	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 no's 30 m 5 mm	Provided Provided Provided	MR MR MR

7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Ground Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➢ Discharge of main Pump</li> <li>➢ Head of Main pump</li> <li>➢ Number of main pumps</li> <li>➢ Jockey Pump out put</li> <li>➢ Jockey pump head</li> <li>➢ Standby Pump out put</li> <li>➢ Standby Pump Head</li> <li>➢ Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➢ Pump House Access</li> <li>• Terrace level <ul style="list-style-type: none"> <li>➢ Discharge of pump</li> <li>➢ Head of the pump</li> <li>➢ Power Supply</li> <li>➢ Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		450 LPM	900 LPM	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Underground tank capacity <ul style="list-style-type: none"> <li>➢ Draw-off connection</li> <li>➢ Fire service inlet</li> <li>➢ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		15,000 ltrs	15,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	No Lift		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A


N73

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note:- As per undertaking submitted by the school management (placed at C- 4) that the school running at stilt, upper ground and first floor only in a building comprised of basement, stilt upper ground floor plus three upper floors, **basement, 2<sup>nd</sup> floor & 3<sup>rd</sup> floor is other's property.** and height of the building is 14.70 meter from ground level to top of terrace level.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010, it's recommended to grant Fire Safety Certificate.

  
 Signature of the Inspecting Officer  
 Name- R.K. Yadav  
 Designation- ADO (DWK)

DO (South West)


  
 RAJINDER ATWAL  
 13/1/26

dy. Cfo (S2)

  
 A.K. MALIK  
 14/1/26

Principal Director

My. Cfo to S2  
 15/01/26

  
 A.K. MALIK  
 DO (S2)  
 16/1/26  
 ADO (DWK)

170