



C/62  
C/62

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/2025/WZ/ 77

Dated: 24/02/2025

To,

Sh. Ashok Agarwal,  
Agarwal Pharmaceuticals,  
B-2644, DSIDC Narela Industrial Complex,  
Delhi-110040.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Agarwal Pharmaceuticals located at  
B-2644, DSIDC Narela Industrial Complex, Delhi- 110040.

Sir,

This has reference to your letter no. E/R/N/24-25-L/56 dated 10/01/2025 received through outdoor diary no. 11309 dated 10/01/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said industrial building has been carried out by officer concerned of this department on 17.02.2025 to see the compliance of the requisite fire safety measures. Sh. Vijay Kumar Sharma was present at the time of inspection.

During the course of inspection it was observed that the building is comprised of Basements, Ground plus Three upper floors while this department had issued FSC vide letter no. F6/DFS/MS/Indl./2022/WZ/57 dated 08/02/2022 for Basements, Ground plus Two upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. First aid hose reels found provided but not functional.
2. Pumping system not found in auto mode.
3. Overhead tank of 2000 ltrs capacity found provided against the required capacity of 4000 ltrs.
4. Exit signages found removed.
5. The third floor is to be removed/ demolished or the third floor is to be regularized from the building sanctioning authority.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

See 2

Copy to:-

1. The District Excise Officer (M & TP), Govt. of NCT of Delhi, L & N Block, Vikas Bhawan, New Delhi.